

# Certificate



for European Product Safety

Reference No. 1224831

## Junction box for luminaires, combined with cord anchorage


Type designation	5637/*
Certificate holder	<b>STEAB S.P.A.</b> <b>Via Ugo Corsi, 15</b> <b>IT-50141 Firenze (FI)</b> <b>ITALY</b>
The product complies with the standard(s)	EN 60598-1:2008+A11
Date of expiry	19 December 2017

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

  
Christer Söderström

Date 19 December 2012  
Page 1 of 2

**Intertek**  
**Appendix**

Reference No. 1224831

*Technical data*

Type designation	5637/*
Rated voltage (V)	250
Rated current (A)	4
IP-Class	20
Brand name:	STEAB
Product information	Junction box for luminaires, combined with cord anchorage. Max 5 x 1,5 mm <sup>2</sup> . T 110.


\* = 1 for base  
2 for cover

- For cable H05VV-F (Ø 8,2 mm) on main supply side
- For single core wires (Ø 2,0 mm) on lampholder side

Manufacturing site(s)      STEAB S.P.A.  
Via G Marconi, 1/3  
P.I.P. Scopeti  
IT-50068 RUFINA (FI)  
ITALY

Certification Body      Intertek Semko AB, Product Certification      Place      Kista - Stockholm

Signed

  
Christer Söderström

Date      19 December 2012

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*