



中国国家强制性产品认证证书

证书编号: 2018011002093971

委托人名称、地址

TCI Telecomunicazioni Italia S.r.l.

Via Parma 14 21047 Saronno (VA) 意大利

生产者(制造商)名称、地址

TCI Telecomunicazioni Italia S.r.l.

Via Parma 14 21047 Saronno (VA) 意大利

生产企业名称、地址

TCI Telecomunicazioni Italia S.r.l.

Via Parma 14 21047 Saronno (VA) 意大利

产品名称和系列、规格、型号

LED 模块用交流电子控制装置(LED 控制装置, 独立式, 恒流模式, 安全特低电压, $t_a: 40^{\circ}\text{C}$, $t_c: 80^{\circ}\text{C}$, II 类, IP20, 适宜直接安装在普通可燃材料表面, 定温热保护: 110°C)

见附件。220-240V~ 50-60Hz

产品标准和技术要求

GB17625.1-2012; GB/T17743-2017; GB19510.1-2009; GB19510.14-200

9

上述产品符合强制性产品认证实施规则 CNCA-C10-01:2014 的要求,
特发此证。

发证日期: 2018 年 07 月 17 日 有效期至: 2023 年 07 月 17 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主 任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2018011002093971

NAME AND ADDRESS OF THE APPLICANT

TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

NAME AND ADDRESS OF THE MANUFACTURER

TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

NAME AND ADDRESS OF THE FACTORY

TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

PRODUCT NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Current Mode, SELV, ta:40°C, tc:80°C, Class II, IP20, Suitable For Direct Mounting On Normally Flammable Material, Temperature Declared Thermally Protected: 110°C)

See Appendix. 220-240V~ 50-60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB17625.1-2012;GB/T17743-2017;GB19510.1-2009;GB19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C10-01:2014).

Valid from: Jul.17,2018

Valid until: Jul.17,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录

第 1 页 共 1 页

证书编号: 2018011002093971

纸 号: 1919985

序号	产品型号	参数			
1	PROFESSIONALE 42	输出: Max. 59Vd. c. , 3-44Vd. c. , 300-1050mA (恒流可调), 配套光源: Max. 42W LED 模块			
输入: 220-240V~, 50-60Hz, Max. 0.23A, λ: 0.95, ta=40℃, tc=80℃, SELV,  ,  ,  , 					
注: PROFESSIONALE 42拨码开关					
输出功率	输出电流	拨码开关位置			
		1	2	3	4
13W	300mA	-	-	-	-
15W	350mA	-	-	-	ON
18W	400mA	-	-	ON	-
20W	450mA	-	-	ON	ON
22W	500mA	-	ON	-	-
24W	550mA	-	ON	-	ON
27W	600mA	-	ON	ON	-
29W	650mA	-	ON	ON	ON
31W	700mA	ON	-	-	-
32W	750mA	ON	-	-	ON
33W	800mA	ON	-	ON	-
35W	850mA	ON	-	ON	ON
38W	900mA	ON	ON	-	-
40W	950mA	ON	ON	-	ON
42W	1000mA	ON	ON	ON	-
42W	1050mA	ON	ON	ON	ON

注: 此附录与证书同时使用时有效。



主 任:





中国质量认证中心