



Certificate of Compliance

Certificate: 1140078 (LL 90483)

Master Contract: 181489

Project: 2107315

Date Issued: 2008/11/06

Issued to: **Salcavi Technic SpA**

Via dell'Industria 1

Talamello, Pesaro 61010

Italy

Attention: Mr. Giancarlo Farinelli

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Kim Nguyen, P. Eng.

Authorized by: Nick Alfano, Operations Manager

PRODUCTS

CLASS 5831 01 - WIRES - Flexible Cord

CLASS 5831 81 - WIRES - Flexible Cord - Certified to US Standards

Thermoplastic PVC insulated Types SPT-1, SPT-2 and SPT-3, 300V, rated at 60°C and 105°C, VW-1, FT2.

Thermoplastic PVC jacketed and insulated Type SVT and SJT, 300V, rated at 60°C and 105°C, VW-1, FT2.

Thermoplastic PVC jacketed and insulated Type ST, 600V, rated at 60°C and 105°C, VW-1, FT2.

APPLICABLE REQUIREMENTS

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1140078 (LL 90483)

Master Contract: 181489

Project: 2107315

Date Issued: 2008/11/06

CSA C22.2 No. 49/UL 62 - Flexible Cords and Cables

Certification Notice

WIRE AND CABLE No. 21 - CSA Certification Markings on CSA Certified Flexible Cords and Cables.