

Certificate of Approval Declared Article

Pursuant to Electricity (Consumer Safety) Act 2004

Certificate Number: NSW26875

Issued to:	Arditi S.p.A	
Class of Article:	Edison Screw Lampholder	
Description of Article:	Edison Screw Lampholder (E27 Porcelain Lampholder)	
Trade Name or Mark:	'Arditi'	
Ratings:	Volts: 250V Amperes: 4A Hertz: 50 Hz	
	Other Name Plate Particulars: T180	
Type Reference Code:	Cat No. 95	
Examined for Compliance With:	AS/NZS 60238 : 2007	
Approval Mark:	Each electrical article of the abovementioned type shall be marked with Approval Number NSW26875 or approved alternate mark NSW23746	
Date of Approval:	17/09/2014	
Approval Expires:	17/09/2019 unless suspended, cancelled, renewed or extended	







ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875 Particulars of Modification(s)

Cat Nos. 90 and 93 being similar to original Cat No.95 except rated 500V, T270 with associated changes.

This certificate will expire on 17/09/2019

Approved: 17 September 2014

For Commissioner for Fair Trading

Energy & Utilities Unit, NSW Fair Trading, PO Box 972, Parramatta NSW 2124 02 9895 0722

Email: energyapprovals@services.nsw.gov.au

Website: www.fairtrading.nsw.gov.au



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875 Particulars of Modification(s)

Addition of series of thermoplastic E27 lampholders, Models A800TP, A801TP, A802TP, A800CI, A801CI, A802CI, A800CA, A801CA, and A802CA, rated 4A/250V, T190;

Addition of series of thermoplastic E14 lampholders, Models 500TP, 600TP and 602TP, rated 2A/250V, T190;

Addition of series of thermoplastic E14 lampholders, Models 50A, 50S, 60A, 60AP, 60S, 62A, 62S, 63, 63A, 64, 64SP, 65, 65F, 65S and 65L, rated 2A/250V, T180 or T210;

Addition of series of thermoplastic E27 lampholders, Models 914, 914CP, 911A, 83F, 83L, 84, 84SP, 85, 85E, 85L, 86, 86A, 87, 87A, 80S, 81S and 82S, rated 4A/250V, T210.

Logo of 'Arditi' may be used as alternate approval mark;

Alternate use of company production facilities in China.

This certificate will expire on 17/09/2019

Approved: 6 February 2015

For Commissioner for Fair Trading

Energy & Utilities Unit, NSW Fair Trading, PO Box 972, Parramatta NSW 2124 02 9895 0722

Email: energyapprovals@services.nsw.gov.au

Website: www.fairtrading.nsw.gov.au



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875 Particulars of Modification(s)

- 1. Model Nos A800TP, A801TP and A802TP now identified by:-
 - (a) Rocker switched Cat No. ref A800/I/TP; A801/I/TP and A802/I/TP respectively; or
 - (b) Pull switched Cat No. ref A800/IT2/TP; A801/IT2/TP and A802/IT2/TP respectively.
- 2. Model Nos. A800 (Cat No. ref A800/I); A801 (Cat No. ref A801/I) and A802 (Cat No. ref A802/I) being similar to

Model Nos A800TP, A801TP and A802TP respectively except for:-

- (a) The use of a Rocker Switch; and
- (b) The use of phenolic material

This certificate will expire on 17/09/2019

Approved:11 July 2016

For Commissioner for Fair Trading 9 August Lake

Email: energyapprovals@services.nsw.gov.au Website: www.fairtrading.nsw.gov.au

Energy & Utilities Unit, NSW Fair Trading, PO Box 972, Parramatta NSW 2124 02 9895 0722



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875

Particulars of Modification(s)

Model 84M is similar to approved Model 84 except for use of screwtype terminals for 2.5mm2 conductor in lieu of spring type.

This certificate will expire on 17/09/2019

Approved: 23 November 2017

For Commissioner for Fair Trading

Email: energyapprovals@finance.nsw.gov.au
Website: www.fairtrading.nsw.gov.au



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875

Change of Particulars

		and the second s
		- 2
		9 2
		ā e
	State:	
	Country:	
Model Ch	nanges	
Model 84M is similar to approved Model 84 except for use of screw type terminals for 0.5mm2 up to 2.5mm2 conductor in lieu of spring type.		
		1
K		
V	State:	
	Country:	7 A
	Model 84M is similar to appr	Model Changes Model 84M is similar to approved Model 84 except for use of terminals for 0.5mm2 up to 2.5mm2 conductor in lieu of sprin

This certificate will expire on 17/09/2019

Approved: 1 February 2018

For Commissioner for Fair Trading



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875 Particulars of Modification(s)

Model No. A800STP and A801STP being similar to Model Nos. A800TP and A801TP respectively except for minor changes to the outer shells.

This certificate will expire on 17/09/2019

Approved: \$\beta 0 July 2018

For Commissioner for Fair Trading

Email: energyapprovals@finance.nsw.gov.au

Website: www.fairtrading.nsw.gov.au

Email: energyapprovals@finance.nsw.gov.au

Website: www.fairtrading.nsw.gov.au



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875

Change of Particulars

Change of Name				
Title:				
New Name:				
ABN:				
ACN:				
Postal Address:				
Suburb:		State:		
Postcode:		Country:		
Model Changes				
Title:				
Model Reference				
Code:				
Trade Name or Mark:				
Other Description:	Approved thermoplastic models are now rated T180 in lieu of T190.			
Manufacturers				
Name:				
Postal Address:				
Suburb:		State:		
Postcode:		Country:		
TI . (.C. ('11 '	17/00/0010			

This certificate will expire on 17/09/2019

Approved: 1 April 2019

For Commissioner for Fair Trading



RENEWAL OF CERTIFICATE OF APPROVAL: NSW26875

Particulars of Renewal

The approval of Edison Screw lampholder Cat No. 95 and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 17/09/2024 unless it is renewed, extended, suspended or cancelled.

For Commissioner for Fair Trading

Email: energyapprovals@finance.nsw.gov.au

Website: www.fairtrading.nsw.gov.au



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW26875 Particulars of Modification(s)

- 1. Cat. No. 95 is de-rated to T180 deg C.
- 2. Cat Nos. A800S/TP, A801S/TP and A802S/TP being similar to Cat Nos. A800/TP, A801/TP and A802/TP respectively except for:-
 - (a) Minor changes to the outer shells; and
 - (b) Both have T180 deg C and T190 deg C ratings.
- 3. Cat Nos. A800S/I/TP, A801S/I/TP and A802S/I/TP being similar to Cat Nos. A800/I/TP, A801/I/TP and A802/I/TP respectively except for minor changes to the outer shells.
- 4. Cat Nos. A800S/IT2/TP, A801S/IT2/TP and A802S/IT2/TP being similar to Cat Nos:-A800/IT2/TP, A801/IT2/TP and A802/IT2/TP respectively except for minor changes to the outer shells.
- 5. Cat Nos. A800/CI, A801/CI and A802/CI are de-rated to T180 deg C.
- The use of the following alternative manufacturing location:-

ARDITI-CN ELECTRIC (HUI Zhou) CO LTD Pan Li Village, Li-Ling Town, Hui Cheng District, Hui Zhou City, Guangdong Province, 516035 China

This certificate will expire on 17/09/2024

Approved: 5 September 2019 For Commissioner for Fair Trading